



# Central Valley Water Reclamation Facility

## CENTRAL VALLEY LOCAL LIMITS Adopted May 2006

Element	30 Day Average (mg/L)	Daily Maximum (mg/L)	Instantaneous Maximum
Arsenic	2.80		
Cadium	2.50		
Chromium Total	48.6		
Copper	11.9		
Cyanide	7.5		
Lead	19.8		
Mercury	0.13		
Molybdenum	3.3		
Nickel	20.4		
Selenium	4.8		
Silver	5.0		
Zinc	18.0		
Oil and Grease (Pet.)		100	
TTO		2.13	
pH			5.0-12.0 *S.U.

\* Standard Units